

January 11, 2017

Mark Knebusch, VP Marketing
Softing Inc.
7209 Chapman Hwy –
Knoxville, TN 37920 - USA

Subject: Softing TM WireXpert WX4500-FA Approval

To whom it may concern

Ortronics is pleased to confirm the approval of the Softing WireXpert Field Test Unit model WX4500 running software version (7.2) or higher for testing Permanent Link and Channel cabling performance up to Category 6A.

This approval is based upon the evaluation of Legrand Data Communications New London Lab comparing the design and results of this tester, versus network analyzer test results for Category 6A/Class EA, Category 6/Class E and Category 5e/Class D system warranties.

The following configuration of WireXpert WX4500 is required to qualify results for warranty Software version (7.2) or higher.

Specific testing requirements with the WireXpert WX4500:

Channel testing for Category 6A/Class EA, Category 6/Class E and Category 5e/Class D using WX-AD-6ACH2 (Category 6A channel adapters, set of 2)

Permanent Link testing for Category 6A/Class EA, Category 6/Class E and Category 5e/Class D using WX-AD-6ALKIT2 (Permanent Link adapters, set of 2).

We will be notifying our sales and training teams who will forward this information to our installers and customers. We will also update our (Ortronics) web site to acknowledge this approval.

We appreciate & look forward to your continued cooperation. I hope this information is of assistance to you and serves your requirements. Should you have any questions or concerns please feel free to contact me.

Regards ,



Gregg Lafontaine
Senior Product Manager for Copper Products
860-405-2904
gregg.lafontaine@legrand.us