



**stewart**  
CONNECTOR  
a bel group

Softing Singapore Pte. Ltd.  
3 Science Park Drive  
The Franklin, #03-09  
Singapore 118223

December 7, 2016

Attention:  
Mr. Simon Harrison  
General Manager

Subject: Softing IT Networks WireXpert™ Approval

Dear Simon,

Effective immediately, Stewart Connector is pleased to announce the approval of WireXpert. This approval is based upon evaluation of WireXpert versus network analyzer by Stewart Connector labs.

WireXpert is approved for use in Channel certification testing with our CAT8.2/CLASS II, CLASS F<sub>A</sub> & F and for Channel and Permanent Link certification testing with our CAT6A/CLASS E<sub>A</sub>, CAT6/CLASS E and CAT5e/CLASS D system warranties.

For CAT8.2/CLASS II systems, the approval includes all parameters to a frequency range of up to 2000 MHz. WireXpert measurements above 2000MHz were also found to have good correlation with network analyzer measurements, and can be used for information.

The following configuration of WireXpert is required:

WireXpert firmware version 7.2 or higher & eXport software version 7.2 or higher

Channel testing CAT8.2/CLASS II	WX_AD_82_ARJCH1 – pair of ARJ45 channel adapters with 2m Stewart Connector ARJ45 test cords.
Channel testing for CLASS F <sub>A</sub> & F	WX_AD_GGARJCH1 – pair of ARJ45 channel adapters with 2m Stewart Connector ARJ45 test cords.
Channel testing for - CAT 6A/CLASS E <sub>A</sub> - CAT 6/CLASS E - CAT 5e/CLASS D	WX_AD_6ACH2 – pair of CAT6A Channel Adapters.
Permanent Link testing for - CAT 6A/CLASS E <sub>A</sub> - CAT 6/CLASS E - CAT 5e/CLASS D	WX_AD_6ALKIT2 – pair of CAT6A Link kits each consisting of a CAT6A Link Adapter.  WX_AD_6ALINK and a Permanent Link test cord WX_AC_6ALCORD.

Sincerely,

Richard D. Marowsky – Principal Electrical Engineer

11118 Susquehanna Trail South  
Glen Rock, PA  
17327 USA

T 717.235.7512  
stewartconnector.com